

Good afternoon

Product recall: Eaton Industries Pty Ltd – Quicklag Residual Circuit Breakers

We have recently been made aware of a product recall for one of the most popular components used in light commercial switchboards across Australia – the Quicklag Residual Circuit Breakers (RCBO). There are potentially millions of these in use across schools through to offices and retail establishments. The recalled RCBOs are manufactured by Eaton Industries Pty Ltd.

The recalled product is the Eaton Quicklag ELQ Earth Leakage Circuit Breaker and the period of supply nationally was from 1 April 2004 and 15 December 2016. The recall notice suggests a non-compliant material has been used in the manufacture of a component, and when operating under short circuit conditions, the product may express ionised gases through the exhaust port which may result in conditions creating a fire risk.

If a client identifies a recalled product, they can fill in an [online form](#) on the Eaton website. Following registration and confirmation of the recalled product, Eaton will arrange for a qualified electrician to attend the client's site and replace the recalled product with the compliant product at no charge.

Further information

Attached is the product recall notice issued by Eaton. You can find further information on the [Eaton website](#) or the [Queensland Workcover website](#).

Kind regards



**STRATA COMMUNITY
INSURANCE**

Rachel Heatley

Underwriting Assistant | Strata Community Insurance



T 1300 SCINSURE (1300 724 678) **D** 07 3071 0010 **W** www.stratacommunityinsure.com.au
A Level 6, 445 Upper Edward Street, Spring Hill QLD 4004 **P** PO Box 881, Spring Hill QLD 4004

This email including any attachments has been sent by Strata Community Insurance Agencies Pty Limited (ABN 72 165 914 009) and is intended for the named recipients only. It may contain privileged or confidential information. If you are not an intended recipient, please delete this email including any attachments and notify the sender. If this email is a commercial electronic message and you would prefer not to receive further commercial electronic messages from us, please forward a copy of this email to compliance@scinsure.com.au with the word unsubscribe in the subject header.